

Annexure C

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. 73 Dated: 05/12/2025
It is certified that an inspection team headed by Samaraya Tripathy A.E. R.W.S. Section BBSR

(Name of Officers with designation) from S.E. R.W.S. Divn BBSR PHED

inspected the Mou. Kiteru Zee School Raghunathpur BBSR - 24

(Name & Address of the school) on 05/12/2025 (date of inspection) and on the basis of
Water Test Report (Attached) bearing no. 15.13 dated 05/12/2025

of State Lab. Khadagiri BBSR (PHED Lab) certified that the

Mou. Kiteru Zee School Raghunathpur BBSR (Name of school) has safe drinking water

facilities for the students and members of staff of the institution. School is also maintains the
hygienic sanitation condition in the school building & the campus as per norms prescribed by the
Central/ State/ U.T. Govt.

This certificate is valid till 04/12/2026

Signature with Seal: [Signature]
Name: Samaraya Tripathy
Designation: Assistant Engineer
Name & Address of the Office / Department: R.W.S. & S Section Bhubaneswar

To PRINCIPAL
Mou. Kiteru Zee School Raghunathpur BBSR - 24
(Name & Address of the Institution)

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies

STATE WATER TESTING LABORATORY, R.W.S.&S. ODISHA

KHANDAGIRI, BHUBANESWAR

Phone – (0674) 2951880; E-mail – rwsscentrallabodisha@gmail.com

No. 15/3/08 /dt 05/12/25

To

**Mount Litera Zee School,
Raghunathpur, Nandankanan Road,
Plot No-1243, Bhubaneswar**

Sub: Test report of water samples

Ref: Your office letter No. Nil/ Dt.03.12.2025

Sir,


The test report of the water samples sent to this Laboratory for testing of Chemical Parameters & Bacteriological Analysis is enclosed herewith for information.

Enclosed: - As above.

Yours faithfully,


Analyst (Chemist)

State Water Testing Laboratory,
RWSS (O)Khandagiri, Bhubaneswar.



C.C. Submitted to:

- Engineer-in-Chief, RWS&S(O), Bhubaneswar for favour of kind information.
- Chief Engineer-I, RWS&S/Chief Engineer-II, RWS&S Odisha, Bhubaneswar for favour of kind information.
- Nodal Officer (WQ), State Water Testing Laboratory, RWSS (O) Khandagiri, Bhubaneswar for favour of kind information.

STATE WATER TESTING LABORATORY, R.W.S.&S., ODISHA KHANDAGIRI, BHUBANESWAR

Phone – (0674) 2951880; E-mail. – rwsscentrallabodisha@gmail.com



WATER ANALYSIS REPORT

TEST REPORT NO.- SWTL-TR/2024/2025/S1-S1
ULR - TC60942500001349F
DATE OF ISSUE -05.12.2025



TC -6094

Sample Particulars		Details of Sample	
Name of the Customer:-	Mount Litera Zee School, Raghunathpur, Nandankanan Road, Plot No-1243, Bhubaneswar	Type of Source:-	Drinking Water/Tap
		Date of Sampling:-	03.12.2025
		Sample receive date:- Vide letter No.	04.12.2025/ Vide letter No. Nil/ Dated /03.12.2025
Sample Package Condition:-		Sample Registration Date:-	04.12.2025
a) Quantity of Sample Received- 1 Ltr.		Sampling Protocol:	Samples are not collected by this laboratory.
b) Type of Container - pp		Sample Collected by:-	Partha Sarathi Patra
		Sample Location:-	Mount Litera Zee School, Raghunathpur, Nandankanan Road, Plot No-1243, Bhubaneswar

TEST RESULT

Test Started on-		05.12.2025		Test Completed on-		05.12.2025	
Sl.	Test Parameters	Units	Results	Requirements IS 10500 : 2012		Test Method	
				Acceptable Limit	Permissible Limit in absence of alternate source		
1	Temperature	°C	1- 25.3	---	---	APHA 24 th Ed., 2023 - 2550 B [Laboratory & Field Methods]	
2	Colour	Hazen Unit	1- 3.0	5	15	APHA 24 th Ed., 2023 - 2120 B [Visual Comparison Method]	
3	pH	pH Unit	1- 6.50	6.5 to 8.5	No relaxation	APHA 24 th Ed., 2023 - 4500 H* B [Electrometric Method]	
4	Conductivity	µmho/cm	1- 53.9	---	---	APHA 24 th Ed., 2023 - 2510 B [Laboratory Method]	
5	Total Hardness (as CaCO ₃)	mg/l	1- 24.0	200	600	APHA 24 th Ed., 2023 - 2340 C [EDTA Titrimetric Method]	
6	Total Alkalinity (as CaCO ₃)	mg/l	1- 16.0	200	600	APHA 24 th Ed., 2023 - 2320 B [Titration Method]	
7	Iron (as Fe)	mg/l	1- 0.044	1.0	No relaxation	APHA 24 th Ed., 2023 - 3500 Fe B [Phenanthroline Method]	
8	Turbidity	NTU	1- 1.33	1.0	5.0	APHA 24 th Ed., 2023 - 2130 B [Nephelometric Method]	

Bacteriological Test

Test Started on-		04.12.2025		Test Completed on-		05.12.2025	
9	Total Coliform Bacteria	Present/Absent per 100ml	1- Absent	Shall not be detectable in any 100 ml Samples		IS 15185 (First Revision): 2016 MFT Method	
10	E.coli	Present/Absent per 100ml	1- Absent				

Note :- The samples were tested with dilution.

Information on Test Report :

Results relates only to samples received in the Laboratory .

The test report shall not be reproduced except in full without written approval of SWTL .

APHA – American Public Health Association /// IS Indian Standard

[Signature]
Microbiologist

Reviewed by

[Signature]
05/12/25
Chemist II

[Signature]
Analyst (Chemist) & Quality Manager.
State Water Testing Laboratory
Authorised Signatory

***** End of Report*****

**STATE WATER TESTING LABORATORY, R.W.S.&S., ODISHA
KHANDAGIRI, BHUBANESWAR**

Phone – (0674) 2951880; E-mail. – rwsscentrallabodisha@gmail.com



WATER ANALYSIS REPORT

TEST REPORT NO.- SWTL-TR/2024/2025/S1-S1

DATE OF ISSUE –05.12.2025

Sample Particulars		Details of Sampling	
Name of the Customer :-	Mount Litera Zee School, Raghunathpur, Nandankanan Road, Plot No-1243, Bhubaneswar	Type of Source:-	Drinking Water/Tap
		Date of Sampling:-	03.12.2025
Sample Package Condition:- a) Quantity of Sample Received – 1 Ltr. b) Type of Container - pp		Sample receive date:- Vide letter No.	04.12.2025/ Vide letter No. Nil/ Dated /03.12.2025
		Sample Registration Date:-	04.12.2025
		Sampling Protocol:-	Samples are not collected by this laboratory.
		Sample Collected by:-	Partha Sarathi Patra
		Sample Location:-	Mount Litera Zee School, Raghunathpur, Nandankanan Road, Plot No-1243, Bhubaneswar

TEST RESULT

Test Started on-		05.12.2025		Test Completed on-		05.12.2025	
Sl.	Test Parameters	Units	Result	Requirements IS 10500 : 2012		Test Method	
				Acceptable Limit	Permissible Limit in absence of alternate source		
1	Odour	---	1- Agreeable	Agreeable	Agreeable	IS 3025 (Part 5) : 2018	
2	Taste	----	1- Agreeable	Agreeable	Agreeable	IS 3025 Part 7 : 2017	

Note :- The samples were tested with dilution.

Information on Test Report :

Results relates only to samples received in the Laboratory .

The test report shall not be reproduced except in full without written approval of SWTL .

APHA – American Public Health Association /// IS Indian Standard

Reviewed by

Chemist II

Analyst (Chemist)

State Water Testing Laboratory,
RWSS(O), Khandagiri, Bhubaneswar

***** End of Report*****